



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 252

Customer

Facility Name: *Perry Traditional Academy*

Address: *3875 Perrysville Ave.
Pittsburgh, PA 15214*

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *9/8/25*

Time: *4:24 PM*

Method: *Grab*

Sample Final Analysis

Date: *9/11/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	9/9/25 10:15 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	9/9/25 10:15 AM	JC	SM 9222B
Standard plate count:	0/ml	A	9/8/25 5:30 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method
pH:	8.0 SU	E	9/8/25 4:24 PM	MM	DPD
Chlorine:	4.0 mg/l	B	9/8/25 4:24 PM	MM	DPD
Turbidity:	1 NTU	A	9/8/25 4:24 PM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor