



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

E-2

Lab# 163

**Customer**

Facility Name: *Holiday Inn Express*

**Sample Collection**

Date: 10/27/25

Address: 3695 State Route 31  
Donegal, PA 15628

Time: 10:13 AM

Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 10/30/25

Source Type: Spa

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/28/25	9:30 AM	JC SM 9222G
Total coliforms:	0/100mls	2/100mls	10/28/25	9:30 AM	JC SM 9222B
Standard plate count:	0/ml	200/ml	10/27/25	5:15 PM	AS SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	10/28/25	12:30 PM	JC SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/27/25	10:13 AM	JC DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	10/27/25	10:13 AM	JC DPD
Turbidity:	1 NTU	1 - 2 NTU	10/27/25	10:13 AM	JC Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor