



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2693**

**Customer**

**Facility Name:** Roaring Run  
**Address:** 194 Tannery Rd  
Champion, PA 15622

**Sample Collection**

**Date:** 7/21/25  
**Time:** 12:24 PM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 7/24/25  
**Time:** 10:00 AM  
**Analyst:** AS

**Source Type:** Baby Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:10 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:10 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/25	12:24 PM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/21/25	12:24 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	12:24 PM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2693**

**Customer**

**Facility Name:** *Roaring Run*  
**Address:** *194 Tannery Rd*  
*Champion, PA 15622*

**Sample Collection**

**Date:** *7/21/25*  
**Time:** *12:24 PM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*

**Sample Final Analysis**

**Date:** *7/24/25*  
**Time:** *10:00 AM*  
**Analyst:** *AS*

**Source Type:** *Baby Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:10 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:10 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/25	12:24 PM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/21/25	12:24 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	12:24 PM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor