



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-10**

**Lab# 2155**

**Customer**

Facility Name: *Dormont Borough Pool*

Address: *1444 Hillsdale Avenue*  
*Pittsburgh, PA 15216*

Matrix: *Recreational Water*

Source Type: *Deep End*

**Sample Collection**

Date: *6/9/25*

Time: *8:56 AM*

Method: *Grab*

**Sample Final Analysis**

Date: *6/12/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	10:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	8:56 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/25	8:56 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	8:56 AM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-10**

**Lab# 2155**

**Customer**

Facility Name: *Dormont Borough Pool*

Address: *1444 Hillsdale Avenue*  
*Pittsburgh, PA 15216*

Matrix: *Recreational Water*

Source Type: *Deep End*

**Sample Collection**

Date: *6/9/25*

Time: *8:56 AM*

Method: *Grab*

**Sample Final Analysis**

Date: *6/12/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	10:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	8:56 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/25	8:56 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	8:56 AM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor