

Matrix:

Source Type:

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 2659

 Customer
 Sample Collection

 Facility Name:
 Camp Redwing
 Date: 7/7/25

 Time:
 11:20 AM

 Address:
 103 Rader School Road
 Method: Grab

 Renfrew, PA 16053
 Renfrew

Sample Final Analysis

Recreational Water Date: 7/10/25
Time: 9:30 AM
Splash Pad Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: Present Absent 7/8/25 11:15 AM EΒ SM 9222G Total coliforms: 10/100mls 2/100mls 7/8/25 11:15 AM EΒ SM 9222B 5:50 PM SL SM 9215B Standard plate count: 5700/ml 200/ml 7/7/25

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/7/25	11:20 AM	ВН	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/7/25	11:20 AM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	11:20 AM	ВН	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Matrix:

Source Type:

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 2659

 Customer
 Sample Collection

 Facility Name:
 Camp Redwing
 Date: 7/7/25

 Time:
 11:20 AM

 Address:
 103 Rader School Road
 Method: Grab

 Renfrew, PA 16053
 Renfrew

Sample Final Analysis

Recreational Water Date: 7/10/25
Time: 9:30 AM
Splash Pad Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: Present Absent 7/8/25 11:15 AM EΒ SM 9222G Total coliforms: 10/100mls 2/100mls 7/8/25 11:15 AM EΒ SM 9222B 5:50 PM SL SM 9215B Standard plate count: 5700/ml 200/ml 7/7/25

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/7/25	11:20 AM	ВН	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/7/25	11:20 AM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	11:20 AM	ВН	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor