



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-17

Lab# 2067

Customer

Facility Name: *Butler Country Club*
Address: *310 Country Club Lane*
Butler, PA 16002

Matrix: *Recreational Water*

Source Type: *Small Pool*

Sample Collection

Date: *6/23/25*
Time: *12:00 AM*
Method: *Grab*

Sample Final Analysis

Date: *6/26/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:40 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	6/23/25	5:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	10:55 AM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/23/25	10:55 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	10:55 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-17

Lab# 2067

Customer

Facility Name: *Butler Country Club*
Address: *310 Country Club Lane*
Butler, PA 16002

Matrix: *Recreational Water*

Source Type: *Small Pool*

Sample Collection

Date: *6/23/25*
Time: *12:00 AM*
Method: *Grab*

Sample Final Analysis

Date: *6/26/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:40 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	6/23/25	5:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	10:55 AM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/23/25	10:55 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	10:55 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor