



Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206 **Lab# 381**
(412) 661-7665
Laboratory Analysis Report

CustomerFacility Name: *PPG Paints Arena***Sample Collection**Date: *2/16/26*Time: *11:45 AM*Method: *Grab*Address: *1001 Fifth Ave
Pittsburgh, PA 15219***Sample Final Analysis**Date: *2/18/26*Time: *10:30 AM*Analyst: *AS*Matrix: *Recreational Water*Source Type: *Cold Plunge*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	2/17/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/17/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/16/26	5:08 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	5.8 SU	7.2 - 7.8 SU	2/16/26	11:45 AM	AG	DPD
Chlorine:	7.4 mg/l	1.0 - 5.0 mg/l	2/16/26	11:45 AM	AG	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/16/26	11:45 AM	AG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor