Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2194

Customer			**Sample Collection**		
Facility Name:	*Forest Hills*		*Date:*	*8/4/25*	
			Time:	10:49 AM	
Address:	*400 Braddock Rd*		*Method:*	*Grab*	
	Pittsburgh, PA 15221				
			Sample Final Analysis		
Matrix:	*Recreational Water*		*Date:*	*8/7/25*	
			Time:	11:20 AM	
Source Type:	*Shallow End*		*Analyst:*	AS	

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	1:36 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25	10:49 AM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/4/25	10:49 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	10:49 AM	EH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2194

Customer

Facility Name:	*Forest Hills*			
Address:	*400 Braddock Rd*			
	Pittsburgh, PA 15221			
Matrix:	*Recreational Water*			
Source Type:	*Shallow End*			

Sample Collection

Date:	*8/4/25*
Time:	10:49 AM
Method:	*Grab*

Sample Final Analysis

Date:	*8/7/25*
Time:	*11:20 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	1:36 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25	10:49 AM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/4/25	10:49 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	10:49 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

_____

Andre Smith, Lead Supervisor