



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 2355**

**Customer**

Facility Name: *Montclair Estates*  
  
Address: *1200 Sherbrook Drive*  
*Pittsburgh, PA 15241*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *8/11/25*  
Time: *12:41 PM*  
Method: *Grab*

**Sample Final Analysis**

Date: *8/14/25*  
Time: *9:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/11/25	12:41 PM	AF	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/11/25	12:41 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	12:41 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Anaë Smith*



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 2355**

**Customer**

Facility Name: *Montclair Estates*  
  
Address: *1200 Sherbrook Drive*  
*Pittsburgh, PA 15241*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *8/11/25*  
Time: *12:41 PM*  
Method: *Grab*

**Sample Final Analysis**

Date: *8/14/25*  
Time: *9:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/11/25	12:41 PM	AF	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/11/25	12:41 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	12:41 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Anaë Smith*