



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2571

Customer

Facility Name: Westmoreland C.C.

Address: 7100 Mellon Rd
Export, PA 15632

Matrix: Recreational Water

Source Type: Wading Pool

Sample Collection

Date: 6/24/25

Time: 12:00 AM

Method: Grab

Sample Final Analysis

Date: 1/0/00

Time: 12:00 AM

Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/0/00	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	6/24/25	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	6/24/25	12:00 AM	0	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2571

Customer

Facility Name: Westmoreland C.C.

Address: 7100 Mellon Rd
Export, PA 15632

Matrix: Recreational Water

Source Type: Wading Pool

Sample Collection

Date: 6/24/25

Time: 12:00 AM

Method: Grab

Sample Final Analysis

Date: 1/0/00

Time: 12:00 AM

Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/0/00	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	6/24/25	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	6/24/25	12:00 AM	0	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor