



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 370

Customer

Facility Name: *Fairfield Inn & Suites*

Address: *189 Finley Road*
Belle Vernon, PA 15012

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/9/25*
Time: *10:55 AM*
Method: *Grab*

Sample Final Analysis

Date: *6/12/25*
Time: *9:30 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/10/25 | 11:15 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/10/25 | 11:15 AM | EB | SM 9222B |
| Standard plate count: | 300/ml | 200/ml | 6/9/25 | 6:20 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/9/25 | 10:55 AM | SH | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 6/9/25 | 10:55 AM | SH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/9/25 | 10:55 AM | SH | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 370

Customer

Facility Name: *Fairfield Inn & Suites*

Address: *189 Finley Road*
Belle Vernon, PA 15012

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/9/25*
Time: *10:55 AM*
Method: *Grab*

Sample Final Analysis

Date: *6/12/25*
Time: *9:30 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/10/25 | 11:15 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/10/25 | 11:15 AM | EB | SM 9222B |
| Standard plate count: | 300/ml | 200/ml | 6/9/25 | 6:20 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/9/25 | 10:55 AM | SH | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 6/9/25 | 10:55 AM | SH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/9/25 | 10:55 AM | SH | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor