



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 10**

**Lab# 079**

**Customer**

**Facility Name:** Courtyard by Marriott  
**Address:** 700 Powerline Drive  
Greensburg, PA 15601

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 7/15/25  
**Time:** 9:11 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/18/25  
**Time:** 9:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/16/25 10:10 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25 10:10 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/25 4:00 PM	AH	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/16/25 11:50 AM	AH	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.2 SU	7.2 - 7.8 SU	7/15/25 9:11 AM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/15/25 9:11 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25 9:11 AM	JC	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 10**

**Lab# 079**

**Customer**

**Facility Name:** Courtyard by Marriott  
**Address:** 700 Powerline Drive  
Greensburg, PA 15601

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 7/15/25  
**Time:** 9:11 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/18/25  
**Time:** 9:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/16/25 10:10 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25 10:10 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/25 4:00 PM	AH	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/16/25 11:50 AM	AH	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.2 SU	7.2 - 7.8 SU	7/15/25 9:11 AM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/15/25 9:11 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25 9:11 AM	JC	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor