



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
S-1

Lab# 024

Customer

Facility Name: Bethel Park High School

Address: 309 Church Rd.
Bethel Park, PA 15102

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 2/17/26

Time: 1:12 PM

Method: Grab

Sample Final Analysis

Date: 2/19/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/18/26 10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/18/26 10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/17/26 5:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/17/26 1:12 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	2/17/26 1:12 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/17/26 1:12 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor