

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 435

Customer Sample Collection

Facility Name: SRU ARC Date: 6/23/25
Time: 2:05 PM

Address: 101 Stadium Dr. Method: Grab

Slippery Rock, PA 16057

Matrix: Recreational Water Sample Final Analysis

Date: 6/26/25

Source Type: Pool Time: 9:00 AM
Analyst: AS

**Accredited Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 6/24/25 10:40 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/24/25 10:40 AM AΗ SM 9222B Standard plate count: 0/ml 200/ml 6/23/25 6:00 PM EΒ SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	6/23/25	2:05 PM	ВН	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/25	2:05 PM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	2:05 PM	вн	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 435

Customer Sample Collection

Facility Name: SRU ARC Date: 6/23/25
Time: 2:05 PM

Address: 101 Stadium Dr. Method: Grab

Slippery Rock, PA 16057

Matrix: Recreational Water Sample Final Analysis

Date: 6/26/25

Source Type: Pool Time: 9:00 AM
Analyst: AS

**Accredited Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 6/24/25 10:40 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/24/25 10:40 AM AΗ SM 9222B Standard plate count: 0/ml 200/ml 6/23/25 6:00 PM EΒ SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	6/23/25	2:05 PM	ВН	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/25	2:05 PM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	2:05 PM	вн	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor