



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 413

Laboratory Analysis Report

Customer

Facility Name: Town Place Airport
Address: 1006 Sutherland Dr.
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/16/25
Time: 12:15 PM
Method: Grab

Sample Final Analysis

Date: 12/19/25
Time: 10:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 12/17/25 | 9:30 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/17/25 | 9:30 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/16/25 | 3:15 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 12/16/25 | 12:15 PM | VH | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 12/16/25 | 12:15 PM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/16/25 | 12:15 PM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor