

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

W-13

Lab ID No. 02-04041

Lab# 2436

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Trellis North Fayette Date: 6/3/25
Time: 10:58 AM

Address: 1500 Park Lane Drive Method: Grab

Pittsburgh, PA 15275

Matrix: Recreational Water Sample Final Analysis

Date: 6/6/25

Time: 9:30 AM

Source Type: Spa Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	9:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	9:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	4:25 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/4/25	12:00 PM	АН	SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/3/25	10:58 AM	АН	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/3/25	10:58 AM	АН	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	10:58 AM	AH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

W-13

Lab ID No. 02-04041

Lab# 2436

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Trellis North Fayette Date: 6/3/25
Time: 10:58 AM

Address: 1500 Park Lane Drive Method: Grab

Pittsburgh, PA 15275

Matrix: Recreational Water Sample Final Analysis

Date: 6/6/25

Time: 9:30 AM

Source Type: Spa Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	9:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	9:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	4:25 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/4/25	12:00 PM	АН	SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/3/25	10:58 AM	АН	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/3/25	10:58 AM	АН	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	10:58 AM	AH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)