Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2322

Customer		*Sample Collection*	
Facility Name:	*Links at Deer Run*	*Date:*	*6/23/25*
		Time:	12:38 PM
Address:	*Links Way*	*Method:*	*Grab*
	Gibsonia, PA 15044		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/26/25*
		Time:	*9:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	4:02 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/23/25	12:38 PM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/25	12:38 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	12:38 PM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer			*Sample Collection*	
Facility Name:	*Links at Deer Run*		*Date:*	*6/23/25*
			Time:	12:38 PM
Address:	*Links Way*		*Method:*	*Grab*
	Gibsonia, PA 15044			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*6/26/25*
			Time:	*9:00 AM*
Source Type:	*Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	4:02 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/23/25	12:38 PM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/25	12:38 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	12:38 PM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor