



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2128**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *Community Swim Club*  
  
*Address:*      *106 Aqua Drive*  
*Pittsburgh, PA 15238*

*Date:*      *6/10/25*  
*Time:*      *1:20 PM*  
*Method:*      *Grab*

**Sample Final Analysis**

*Matrix:*      *Recreational Water*  
  
*Source Type:*      *Deep End*

*Date:*      *6/13/25*  
*Time:*      *9:30 AM*  
*Analyst:*      *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	6/11/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	4:50 PM	SL	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.4 SU	7.2 - 7.8 SU	6/10/25	1:20 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/10/25	1:20 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	1:20 PM	BH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2128**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Community Swim Club*

*Date: 6/10/25*

*Address: 106 Aqua Drive*  
*Pittsburgh, PA 15238*

*Time: 1:20 PM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 6/13/25*

*Time: 9:30 AM*

*Source Type: Deep End*

*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	4:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/10/25	1:20 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/10/25	1:20 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	1:20 PM	BH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor