



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N - 1**

**Lab# 492**

**Customer**

Facility Name: Wildwood British Swim School

Address: 2344 Wildwood Rd.  
Gibsonia, PA 15044

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 11/24/25

Time: 10:10 AM

Method: Grab

**Sample Final Analysis**

Date: 11/27/25

Time: 12:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/25/25	12:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/25/25	12:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	11/24/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	11/24/25	10:10 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/24/25	10:10 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/24/25	10:10 AM	BH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)