



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

N-17

Lab# 2347

**Customer**

Facility Name: Meadowbrook Apt

**Sample Collection**

Date: 8/4/25

Address: 13 Meadow Brook Lane  
Butler, PA 16001

Time: 1:25 PM

Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 8/7/25

Source Type: Pool

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	12:15 PM	AS
Total coliforms:	0/100mls	2/100mls	8/5/25	12:15 PM	AS
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/4/25	1:25 PM	BH
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25	1:25 PM	BH
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	1:25 PM	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-17

Lab# 2347

**Customer**

Facility Name: Meadowbrook Apt

Address: 13 Meadow Brook Lane  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 8/4/25

Time: 1:25 PM

Method: Grab

**Sample Final Analysis**

Date: 8/7/25

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	12:15 PM	AS
Total coliforms:	0/100mls	2/100mls	8/5/25	12:15 PM	AS
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/4/25	1:25 PM	BH
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25	1:25 PM	BH
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	1:25 PM	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor