



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2113

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	Clinton Lake	<b><u>Sample Collection</u></b>
		Date: 7/1/25
Address:	124 Clinton Dr. Clinton, PA 15026	Time: 1:29 PM
		Method: Grab
Matrix:	Recreational Water	<b><u>Sample Final Analysis</u></b>
		Date: 7/4/25
Source Type:	Pool	Time: 9:30 AM
		Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/2/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	10:40 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	7/1/25	4:30 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	7/1/25	1:29 PM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	1:29 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	1:29 PM	AH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2113

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	Clinton Lake	<b><u>Sample Collection</u></b>
		Date: 7/1/25
Address:	124 Clinton Dr. Clinton, PA 15026	Time: 1:29 PM
		Method: Grab
Matrix:	Recreational Water	<b><u>Sample Final Analysis</u></b>
		Date: 7/4/25
Source Type:	Pool	Time: 9:30 AM
		Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/2/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	10:40 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	7/1/25	4:30 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	7/1/25	1:29 PM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	1:29 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	1:29 PM	AH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor