



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2517

Customer

Facility Name: Sylvan Ridge(sunnyhill Apts.)

Address: 130 Sunnyhill Dr.
Beaver Falls, PA 15010

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/28/25

Time: 4:48 PM

Method: Grab

Sample Final Analysis

Date: 7/31/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	7:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/28/25	4:48 PM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/28/25	4:48 PM	AH	DPD
Turbidity:	3 NTU	1 - 2 NTU	7/28/25	4:48 PM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2517

Customer

Facility Name: Sylvan Ridge(sunnyhill Apts.)

Address: 130 Sunnyhill Dr.
Beaver Falls, PA 15010

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/28/25

Time: 4:48 PM

Method: Grab

Sample Final Analysis

Date: 7/31/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	7:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/28/25	4:48 PM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/28/25	4:48 PM	AH	DPD
Turbidity:	3 NTU	1 - 2 NTU	7/28/25	4:48 PM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor