

## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

**APM 1** 

Lab# 2063

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brook Park Swim Club

Address: 8190 Rochester Rd

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

 Date:
 7/8/25

 Time:
 1:16 PM

 Method:
 Grab

Sample Final Analysis

 Date:
 7/11/25

 Time:
 9:00 AM

 Analyst:
 AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/9/25	10:40 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/9/25	10:40 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	AS	SM 9215B	

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	7/8/25	1:16 PM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/8/25	1:16 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	1:16 PM	MM	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

**APM 1** 

Lab# 2063

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brook Park Swim Club

Address: 8190 Rochester Rd

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

 Date:
 7/8/25

 Time:
 1:16 PM

 Method:
 Grab

Sample Final Analysis

 Date:
 7/11/25

 Time:
 9:00 AM

 Analyst:
 AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/9/25	10:40 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/9/25	10:40 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	AS	SM 9215B	

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	7/8/25	1:16 PM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/8/25	1:16 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	1:16 PM	MM	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor