

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

N-10

Lab ID No. 02-04041

Lab# 227

Customer Sample Collection

Facility Name: Mews I Date: 8/5/25
Time: 11:30 AM

Address: 300 Fox Chapel Rd. Method: Grab

Pittsburgh, PA 15238

Matrix: Recreational Water Sample Final Analysis

Date: 8/8/25

Source Type: Pool Time: 8:30 AM
Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 8/6/25 2:00 PM AH SM 9222G Total coliforms: 0/100mls 2/100mls 8/6/25 2:00 PM AΗ SM 9222B Standard plate count: 0/ml 200/ml 8/5/25 5:40 PM AS SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	8/5/25	11:30 AM	ВН	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/5/25	11:30 AM	ВН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:30 AM	ВН	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

N-10

Lab ID No. 02-04041

Lab# 227

Customer Sample Collection

Facility Name: Mews I Date: 8/5/25
Time: 11:30 AM

Address: 300 Fox Chapel Rd. Method: Grab

Pittsburgh, PA 15238

Matrix: Recreational Water Sample Final Analysis

Date: 8/8/25

Source Type: Pool Time: 8:30 AM
Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 8/6/25 2:00 PM AH SM 9222G Total coliforms: 0/100mls 2/100mls 8/6/25 2:00 PM AΗ SM 9222B Standard plate count: 0/ml 200/ml 8/5/25 5:40 PM AS SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	8/5/25	11:30 AM	ВН	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/5/25	11:30 AM	ВН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:30 AM	ВН	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor