



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2024

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Avalon Boro
Address: 629 New Brighton Rd.
Avalon, PA 15202

Date: 6/10/25
Time: 10:25 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Shallow End

Date: 6/13/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25 11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25 11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25 5:50 PM	SL	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/10/25 10:25 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/10/25 10:25 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25 10:25 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2024

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Avalon Boro
Address: 629 New Brighton Rd.
Avalon, PA 15202

Date: 6/10/25
Time: 10:25 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Shallow End

Date: 6/13/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25 11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25 11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25 5:50 PM	SL	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/10/25 10:25 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/10/25 10:25 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25 10:25 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor