



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 331

Customer

Facility Name: West Mifflin High School.

Sample Collection

Date: 2/9/26

Address: 91 Commonwealth Avenue
West Mifflin, PA 15122

Time: 8:25 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 2/12/26

Source Type: Pool Deep

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/10/26	10:00 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	2/10/26	10:00 AM	SL SM 9222B
Standard plate count:	0/ml	200/ml	2/9/26	5:20 PM	SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/9/26	8:25 AM	SH DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/9/26	8:25 AM	SH DPD
Turbidity:	1 NTU	1 - 2 NTU	2/9/26	8:25 AM	SH Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor