



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-13**

**Lab# 2388**

**Customer**

**Facility Name:** Oxford Athletic  
**Address:** 100 Village Club Dr.  
Wexford, PA 15090  
**Matrix:** Recreational Water  
**Source Type:** Spray Pad

**Sample Collection**

**Date:** 7/14/25  
**Time:** 2:59 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/17/25  
**Time:** 8:30 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/15/25              | 11:15 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/15/25              | 11:15 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/14/25              | 5:30 PM  | EB      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 8.0 SU   | 7.2 - 7.8 SU    | 7/14/25   | 2:59 PM | MM      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 7/14/25   | 2:59 PM | MM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/14/25   | 2:59 PM | MM      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-13**

**Lab# 2388**

**Customer**

Facility Name: Oxford Athletic  
Address: 100 Village Club Dr.  
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Spray Pad

**Sample Collection**

Date: 7/14/25  
Time: 2:59 PM  
Method: Grab

**Sample Final Analysis**

Date: 7/17/25  
Time: 8:30 AM  
Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/15/25              | 11:15 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/15/25              | 11:15 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/14/25              | 5:30 PM  | EB      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 8.0 SU   | 7.2 - 7.8 SU    | 7/14/25   | 2:59 PM | MM      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 7/14/25   | 2:59 PM | MM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/14/25   | 2:59 PM | MM      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor