



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# 2267

**Customer**

Facility Name: Hillcrest Country Club

Address: 3411 Leechburg Road  
Lower Burrell, PA 15068

Matrix: Recreational Water

Source Type: Small Pool

**Sample Collection**

Date: 5/28/25

Time: 11:55 AM

Method: Grab

**Sample Final Analysis**

Date: 5/31/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25 10:05 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25 10:05 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25 5:36 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	5/28/25 11:55 AM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/28/25 11:55 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25 11:55 AM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# 2267

**Customer**

Facility Name: Hillcrest Country Club

Address: 3411 Leechburg Road  
Lower Burrell, PA 15068

Matrix: Recreational Water

Source Type: Small Pool

**Sample Collection**

Date: 5/28/25

Time: 11:55 AM

Method: Grab

**Sample Final Analysis**

Date: 5/31/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:05 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	10:05 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	5:36 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	5/28/25	11:55 AM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:55 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:55 AM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor