



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2107**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *City Vista Apts*      *Date:*      *8/18/25*  
*Address:*      *325 Elizabeth Dr.*      *Time:*      *3:00 PM*  
*Pittsburgh, PA 15220*      *Method:*      *Grab*

**Sample Final Analysis**

*Matrix:*      *Recreational Water*      *Date:*      *8/21/25*  
*Source Type:*      *Pool*      *Time:*      *9:00 AM*  
*Analyst:*      *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/25	10:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/25	10:30 AM	SL	SM 9222B
Standard plate count:	20/ml	200/ml	8/18/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.9 SU	7.2 - 7.8 SU	8/18/25	3:00 PM	CW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/18/25	3:00 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/25	3:00 PM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor