



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2375

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name:	Address:	<u>Sample Collection</u>				
		Date:	7/14/25	Time:	12:30 PM	
Matrix:	Source Type:	<u>Sample Final Analysis</u>				
Escherichia Coli:	Total coliforms:	Date:	7/17/25	Time:	8:30 AM	
		Analyst:	AS	Analyst:	AS	
Recreational Water	Pool					
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	7/14/25	3:16 PM	AH	SM 9215B

<u>Field Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	12:30 PM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/14/25	12:30 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	12:30 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2375

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name:	Address:	<u>Sample Collection</u>				
		Date:	7/14/25	Time:	12:30 PM	
Matrix:	Source Type:	<u>Sample Final Analysis</u>				
Escherichia Coli:	Total coliforms:	Date:	7/17/25	Time:	8:30 AM	
		Analyst:	AS	Analyst:	AS	
Recreational Water	Pool					
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	7/14/25	3:16 PM	AH	SM 9215B

<u>Field Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	12:30 PM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/14/25	12:30 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	12:30 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor