

Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
APM 2

Lab# 2129

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 5/28/25
Time: 2:40 PM
Method: Grab

Sample Final Analysis

Date: 5/31/25
Time: 9:30 AM
Analyst: AS

Facility Name: Community Swim Club

Address: 106 Aqua Drive
Pittsburgh, PA 15238

Matrix: Recreational Water


Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	3:50 PM	AH	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/28/25	2:40 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/28/25	2:40 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	2:40 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
APM 2

Lab# 2129

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 5/28/25
Time: 2:40 PM
Method: Grab

Sample Final Analysis

Date: 5/31/25
Time: 9:30 AM
Analyst: AS

Facility Name: Community Swim Club
Address: 106 Aqua Drive
Pittsburgh, PA 15238
Matrix: Recreational Water
Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	3:50 PM	AH	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/28/25	2:40 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/28/25	2:40 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	2:40 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor