



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-2**

**Lab# 141**

**Customer**

Facility Name: *Heinz House*  
Address: *1 Heinz St.*  
*Pittsburgh, PA 15212*

**Sample Collection**

Date: *11/11/25*  
Time: *2:15 PM*  
Method: *Grab*

Matrix: *Recreational Water*

**Sample Final Analysis**

Date: *11/14/25*  
Time: *10:30 AM*  
Analyst: *AS*

Source Type: *Pool Shallow*

| Accredited Analysis   | Results  | Reporting limit | Incubation | Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 11/12/25   | 10:00 AM  | JC      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 11/12/25   | 10:00 AM  | JC      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 11/11/25   | 4:35 PM   | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 11/11/25  | 2:15 PM | BH      | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 11/11/25  | 2:15 PM | BH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 11/11/25  | 2:15 PM | BH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor