



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2151

Customer

Facility Name: *Devilins Pointe*

Address: *2857 Oxford Boulevard*
Allison Park, PA 15101

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/30/25*

Time: *10:14 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/3/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	6/30/25	10:14 AM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/30/25	10:14 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:14 AM	GR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2151

Customer

Facility Name: Devlins Pointe

*Address: 2857 Oxford Boulevard
Allison Park, PA 15101*

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/30/25

Time: 10:14 AM

Method: Grab

Sample Final Analysis

Date: 7/3/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	6/30/25	10:14 AM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/30/25	10:14 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:14 AM	GR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor