



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2030**

**Customer**

**Facility Name:** *Barrington Manor*  
**Address:** *200 Barrington Dr.*  
*Oakdale, PA 15071*

**Sample Collection**

**Date:** *7/22/25*  
**Time:** *8:04 AM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *7/25/25*  
**Time:** *10:00 AM*  
**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/22/25	8:04 AM	AH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/22/25	8:04 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	8:04 AM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2030**

**Customer**

**Facility Name:** Barrington Manor  
**Address:** 200 Barrington Dr.  
Oakdale, PA 15071

**Sample Collection**

**Date:** 7/22/25  
**Time:** 8:04 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/25/25  
**Time:** 10:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/22/25	8:04 AM	AH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/22/25	8:04 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	8:04 AM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor