



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 245

Customer

Facility Name: Oxford Athletic Club

Address: 100 Village Club Dr.
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 9/17/25

Time: 9:45 AM

Method: Grab

Sample Final Analysis

Date: 9/19/25

Time: 2:00 PM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 9/17/25 | 3:25 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/17/25 | 3:25 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 9/17/25 | 3:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 9/17/25 | 9:45 AM | VH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 9/17/25 | 9:45 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/17/25 | 9:45 AM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor