



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 2035**

**Customer**

**Facility Name:** Bellevue Borough  
**Address:** 322 Bellevue Rd.  
Pittsburgh, PA 15202

**Sample Collection**

**Date:** 8/11/25  
**Time:** 3:49 PM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 8/14/25  
**Time:** 9:00 AM  
**Analyst:** AS

**Source Type:** Baby Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	6:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	3:49 PM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/11/25	3:49 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	3:49 PM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 2035**

**Customer**

**Facility Name:** Bellevue Borough  
**Address:** 322 Bellevue Rd.  
Pittsburgh, PA 15202

**Sample Collection**

**Date:** 8/11/25  
**Time:** 3:49 PM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 8/14/25  
**Time:** 9:00 AM  
**Analyst:** AS

**Source Type:** Baby Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	6:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	3:49 PM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/11/25	3:49 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	3:49 PM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor