



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 165

Customer

Facility Name: *Holiday Inn Express - North Shore*

Address: *228 Federal St.
Pittsburgh, PA 15212*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *8/27/25*

Time: *2:40 PM*

Method: *Grab*

Sample Final Analysis

Date: *8/30/25*

Time: *8:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/28/25	10:40 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/28/25	10:40 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/27/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/27/25	2:40 PM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/27/25	2:40 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/27/25	2:40 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor