

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 382

7/21/25

Customer Sample Collection

Facility Name: Hilton Garden Inn Date:

Address: 9600 University Blvd Time: 8:45 AM Method: Grab

Pittsburgh, PA 15108

Matrix: Recreational Water Sample Final Analysis
Date: 7/24/25
Time: 10:00 AM

Source Type: Pool Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/22/25	12:00 PM	SL	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/22/25	12:00 PM	SL	SM 9222B	
Standard plate count:	0/ml	200/ml	7/21/25	6:40 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/21/25	8:45 AM	АН	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/21/25	8:45 AM	АН	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	8:45 AM	АН	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 382

7/21/25

Customer Sample Collection

Facility Name: Hilton Garden Inn Date:

Address: 9600 University Blvd Time: 8:45 AM Method: Grab

Pittsburgh, PA 15108

Matrix: Recreational Water Sample Final Analysis
Date: 7/24/25
Time: 10:00 AM

Source Type: Pool Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/22/25	12:00 PM	SL	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/22/25	12:00 PM	SL	SM 9222B	
Standard plate count:	0/ml	200/ml	7/21/25	6:40 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/21/25	8:45 AM	АН	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/21/25	8:45 AM	АН	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	8:45 AM	АН	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor