

## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 10

Lab# 077

Sample Collection Customer

Facility Name: Courtyard by Marriott Date: 5/29/25

4:15 PM Time: Address: 700 Powerline Drive Method: Grab

Greensburg, PA 15601

Sample Final Analysis Recreational Water 5/31/25 Matrix: Date:

Time: 3:30 PM

Source Type: Pool AS Analyst:

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25	6:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	limit Date/Time		Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	5/29/25	4:15 PM	ВН	DPD	
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/29/25	4:15 PM	ВН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	4:15 PM	ВН	Visual	

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 10

Lab# 077

Sample Collection Customer

Facility Name: Courtyard by Marriott Date: 5/29/25

4:15 PM Time: Address: 700 Powerline Drive Method: Grab

Greensburg, PA 15601

Sample Final Analysis Recreational Water 5/31/25 Matrix: Date:

Time: 3:30 PM

Source Type: Pool AS Analyst:

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25	6:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	limit Date/Time		Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	5/29/25	4:15 PM	ВН	DPD	
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/29/25	4:15 PM	ВН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	4:15 PM	ВН	Visual	

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor