



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2604

Customer

Facility Name: Wyngate Swim Club
Address: 100 North Jamestown Rd.
Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 6/16/25
Time: 9:17 AM
Method: Grab

Sample Final Analysis

Date: 6/19/25
Time: 10:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/17/25 | 12:00 PM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/17/25 | 12:00 PM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/16/25 | 6:00 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 6/16/25 | 9:17 AM | AH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/16/25 | 9:17 AM | AH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/16/25 | 9:17 AM | AH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2604

Customer

Facility Name: Wyngate Swim Club
Address: 100 North Jamestown Rd.
Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 6/16/25
Time: 9:17 AM
Method: Grab

Sample Final Analysis

Date: 6/19/25
Time: 10:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/17/25 | 12:00 PM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/17/25 | 12:00 PM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/16/25 | 6:00 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
|----------------|----------|-----------------|---------|-----------|---------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 6/16/25 | 9:17 AM | AH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/16/25 | 9:17 AM | AH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/16/25 | 9:17 AM | AH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor