



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
C-2

Lab# 446

Customer

Facility Name: Comfort Inn
Address: 830 East Ohio St.
Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/30/25
Time: 12:00 AM
Method: Grab

Sample Final Analysis

Date: 10/3/25
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/1/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/1/25	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/30/25	4:07 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	9/30/25	12:40 PM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	9/30/25	12:40 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/30/25	12:40 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor