



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2091

Customer

Facility Name: Chapel Gate Swim Club

Sample Collection

Date: 6/3/25

Address: Glen David Drive
Pittsburgh, PA 15238

Time: 3:35 PM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/6/25

Source Type: Deep End

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	10:20 AM	EB
Total coliforms:	0/100mls	2/100mls	6/4/25	10:20 AM	EB
Standard plate count:	0/ml	200/ml	6/3/25	4:45 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/3/25	3:35 PM	BH
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/3/25	3:35 PM	BH
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	3:35 PM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2091

Customer

Facility Name: Chapel Gate Swim Club

Sample Collection

Date: 6/3/25

Address: Glen David Drive
Pittsburgh, PA 15238

Time: 3:35 PM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/6/25

Source Type: Deep End

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	10:20 AM	EB
Total coliforms:	0/100mls	2/100mls	6/4/25	10:20 AM	EB
Standard plate count:	0/ml	200/ml	6/3/25	4:45 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/3/25	3:35 PM	BH
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/3/25	3:35 PM	BH
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	3:35 PM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor