



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 270**

**Customer**

Facility Name: Science and Technology Academy

Address: 107 Thackeray St.  
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 5/29/25

Time: 11:45 AM

Method: Grab

**Sample Final Analysis**

Date: 5/31/25

Time: 3:30 PM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	5/29/25	6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	5/29/25	6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	A	5/29/25	6:05 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	5/29/25	11:45 AM	DW	DPD
Chlorine:	3.0 mg/l	A	5/29/25	11:45 AM	DW	DPD
Turbidity:	1 NTU	A	5/29/25	11:45 AM	DW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 270**

**Customer**

Facility Name: Science and Technology Academy

Address: 107 Thackeray St.  
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 5/29/25

Time: 11:45 AM

Method: Grab

**Sample Final Analysis**

Date: 5/31/25

Time: 3:30 PM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	5/29/25	6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	5/29/25	6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	A	5/29/25	6:05 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	5/29/25	11:45 AM	DW	DPD
Chlorine:	3.0 mg/l	A	5/29/25	11:45 AM	DW	DPD
Turbidity:	1 NTU	A	5/29/25	11:45 AM	DW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor