



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 092

Customer

Facility Name: Doubletree Hotel
Address: 101 Doubletree Dr.
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 10/7/25
Time: 8:02 AM
Method: Grab

Sample Final Analysis

Date: 10/10/25
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	10/8/25 11:30 AM	JC	SM 9222G
-------------------	--------	--------	------------------	----	----------

Total coliforms:	0/100mls	2/100mls	10/8/25 11:30 AM	JC	SM 9222B
------------------	----------	----------	------------------	----	----------

Standard plate count:	570/ml	200/ml	10/7/25 5:30 PM	AS	SM 9215B
-----------------------	--------	--------	-----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	10/8/25 12:00 PM	JC	SM 9213C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	10/7/25 8:02 AM	MM	DPD
-----	--------	--------------	-----------------	----	-----

Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	10/7/25 8:02 AM	MM	DPD
-----------	----------	----------------	-----------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	10/7/25 8:02 AM	MM	Visual
------------	-------	-----------	-----------------	----	--------

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor