Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2300

Customer			*Sample Collection*	
Facility Name:	*Jefferson Point*		*Date:*	*6/11/25*
			Time:	10:25 AM
Address:	*6400 Jefferson Point Circle*		*Method:*	*Grab*
	Jefferson Hills, PA 15025			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*6/13/25*
			Time:	*3:00 PM*
Source Type:	*Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	3:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	3:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25	3:33 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/11/25	10:25 AM	DW	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/11/25	10:25 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	10:25 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2300

Customer

			Sample Collection	
Facility Name:	*Jefferson Point*		*Date:*	*6/11/25*
			Time:	10:25 AM
Address:	*6400 Jefferson Point Circle*		*Method:*	*Grab*
	Jefferson Hills, PA 15025			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*6/13/25*
			Time:	3:00 PM
Source Type:	*Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	3:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	3:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25	3:33 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/11/25	10:25 AM	DW	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/11/25	10:25 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	10:25 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor