



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-2**

**Lab# 338**

**Customer**

**Facility Name:** White Oak Village  
**Address:** 152 Royal Oak Drive  
McKeesport, PA 15131

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 10/20/25  
**Time:** 3:00 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 10/23/25  
**Time:** 10:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/21/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/21/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/20/25	4:06 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	10/20/25	3:00 PM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/20/25	3:00 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/20/25	3:00 PM	JC	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor