



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 161

Customer

Facility Name: Holiday Inn Express

Address: 10 Landings Dr.
Harmarville, PA 15238

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 1/21/26

Time: 7:15 AM

Method: Grab

Sample Final Analysis

Date: 1/24/26

Time: 8:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 1/22/26 | 10:00 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 1/22/26 | 10:00 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 1/21/26 | 5:21 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 1/21/26 | 7:15 AM | AMH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 1/21/26 | 7:15 AM | AMH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 1/21/26 | 7:15 AM | AMH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor