



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2161**

**Customer**

Facility Name: *Eagle Trace*  
Address: *300 Allandale Dr.*  
*Bethel Park, PA 15102*

**Sample Collection**

Date: *6/4/25*  
Time: *3:00 PM*  
Method: *Grab*

Matrix: *Recreational Water*  
Source Type: *Pool*

**Sample Final Analysis**

Date: *6/6/25*  
Time: *4:00 PM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	6:50 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	6:50 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	6:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/4/25	3:00 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/4/25	3:00 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	3:00 PM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2161**

**Customer**

Facility Name: *Eagle Trace*  
Address: *300 Allandale Dr.*  
*Bethel Park, PA 15102*

**Sample Collection**

Date: *6/4/25*  
Time: *3:00 PM*  
Method: *Grab*

Matrix: *Recreational Water*  
Source Type: *Pool*

**Sample Final Analysis**

Date: *6/6/25*  
Time: *4:00 PM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	6:50 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	6:50 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	6:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/4/25	3:00 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/4/25	3:00 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	3:00 PM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor