Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

B & R Pools and Swim Shop

Customer		**Sample Collection**	
Facility Name:	*Duffy Highlands*	*Date:*	*7/21/25*
		Time:	1:00 PM
Address:	*200 Muirfield Ct.*	*Method:*	*Grab*
	Butler, PA 16001		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/24/25*
		Time:	*10:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/25	1:00 PM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/21/25	1:00 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	1:00 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer		_Sample Collection_	
Facility Name:	*Duffy Highlands*	*Date:*	*7/21/25*
		Time:	1:00 PM
Address:	*200 Muirfield Ct.*	*Method:*	*Grab*
	Butler, PA 16001		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/24/25*
		Time:	*10:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/25	1:00 PM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/21/25	1:00 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	1:00 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor