



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-1**

**Lab# 365**

**Customer**

**Facility Name:** YMCA - Sewickley  
  
**Address:** 625 Blackburn Rd.  
Sewickley, PA 15143

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 10/27/25  
**Time:** 11:13 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 10/30/25  
**Time:** 10:30 AM  
**Analyst:** AS

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	10/28/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/28/25	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/27/25	5:15 PM	AS	SM 9215B
<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Fecal Streptococcus	0/100mls	2/100mls	10/28/25	12:30 PM	JC	SM 9230C
<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.0 SU	7.2 - 7.8 SU	10/27/25	11:13 AM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/27/25	11:13 AM	AMH	DPD
Turbidity:	3 NTU	1 - 2 NTU	10/27/25	11:13 AM	AMH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor